



Using GIS to calculate the potential for small hydro power plants in Norway

Astrid Voksø, NVE

Olav Kavli, Geodata AS

Hallvard Stensby, NVE



Outline

- Background
- Concept
- The projects aim
- Description of Analysis and conditions
- Results
- Problems solved



Background

- Unknown potential
- Demanding work to do manually
- Manually calculation gives different results
- Newly developed datasets at NVE (river network, DTM, digital runoff map as grid)
- NVEs GIS-expertise



Concept

- Identify slope with a certain derived gradient using DTM and river network.
- Calculate drainage area and runoff
- Identify slope with enough energy potential
- Consultant available Geodata AS v/Olav Kavli with knowledge to implement in ArcGIS



Aim

- Calculate small hydro plants energy potential
- Rough estimate
- Automatic using digital maps and GIS, manual correction
- **RESULT:** the theoretical potential for small hydro power plants .




Steps in the Analysis

- Preparation of DTEM
 - Including hydrologic analysis
- Generate geometric river network from cover to PGDB
- Calculate distance to roads and power lines
- The analyses

Prepare DTEM - 25 x 25 meters

- Compare with digitized watersheds
- Correct errors by elevate terrain 10 m





Prepare DTEM


- Compare with digitized watersheds
- Correct errors by elevate terrain 10 m
- New DTEM
 - Get points from DTEM - gridpoint
 - Topogrid - gridpoint and river network as stream



Derive runoff

Calculate watershed in all points along river – time-consuming - instead


- Arc/Info standard hydrologic analyses
 - Flow direction – determine the direction of flow from every cell in the raster





Derive runoff


- Arc/Info standard hydrologic analysis
 - flow direction - determine the direction of flow
 - flow accumulation - calculates accumulated flow as the accumulated number of all cells flowing into each down slope cell in the output raster.






Derive runoff


- Arc/Info standard hydrologic analysis
 - flow accumulation with runoff as a weight raster - accumulated weight of all cells flowing into each down slope cell in the output raster.






Change flowdir and flowacc for regulated rivers

Use setmask when flowacc is generated




River network

- Centre line generated for all rivers defined in REGINE
 - Joined in nodes and given direction towards outlet – river network on cover
- Irrelevant with power plant where intake and power plant on each side of lake
 - Erase centreline in lakes and generate new outlet points



Rivers outside river network

- Generate automatic from DTEM
- 300 cells in flowdir to define a river comparable to 1:50.000
- Join both datasets
- New outlet points



So fare analyse in Arc/Info workstation




Prepare datasets in ArcGIS


- Convert centreline of river and outlet points to PGDB.
- Generate topology and correct errors.
- Convert river network and outlet points to 3D.
- Generate geometric network
- Find and correct network errors



Example error in geometric network



Example error in geometric network






Steps in the analyse


- Identify downfall
 - Calculate longitude profile
 - Identify downfall with gradient $> 1:25$
 - Find top and bottom of each downfall
 - Calculate attribute to top of each downfall
- Identify small hydro power plants which are within the conditions
- Calculate cost for each plant



Calculate profile

- Use "utility network analysis" to trace all rivers from outlet to top
 - Each trace – longitude profile stored temporary
 - Dived profile in 50 meter sections – define point for each section (represent at top)
 - Attributes: difference of height, dH/dL .





dH/dL for each 50 meter


< 0.04 - black vs. 1:25

> 0.04 - green



■ Identify downfall

- from outlet trace all profile points and start a downfall where $dH/dL > 0.04$ and end where dH/dL gets < 0.04 .




Blue triangle → intake

Yellow circle → power plant



- Calculate parameters at top of each downfall
 - Drainage area (flowacc)
 - Runoff (flowacc weighted with runoff grid)
 - Total difference of height
 - NB! - flowacc is calculated from the DTEM, that means that basis is the generated river



Blue river - generate from DTEM

Red boundary – REGINE's watersheds



Conditions

- All rivers with downfall down to 1:25
- Relevant elevation limits (H) is 10 m - 600 m.
- Runoff 0.05 m³/s – 25 m³/s
- The turbine's maximum useable flow -
(Q) = 1,5 x Q_{av} (average runoff).
- Installed power - $N = 8,0 \times Q \times H$
- Installed power limits - 50 kW-10000 kW.
- Production - 70 % of water can be used
- Production = $8,0 \times (\text{Volume pr year}) \times 0,7 \times H \times / 3600$

Erase plants outside defined limitations






Cost accounting

- Formula developed for small hydro plants
- Calculated based on
 - Elevation
 - Length of pipeline
 - Maximum useable flow
 - Distance to roads and transmission lines
 - Power

Results

Calculate for each drainage basin





Identify Results

Layers: <Top-most layer>

Inntak

- 204.z_4

Location: (698542,662343 7677072,582475)

Field	Value
OBJECTID	363
Shape	Point
KrvID	204.z_4
mKvID	204.z_698555_7677069
ProfilID	1
Vannforing	0,215244
NedbFeltAreal	5,70625
ProdFaktor	0,7
InntakIVatn	0

Identify Results

Layers: Kraftverk

- 204.z_698555_76770
- 204.z_698811_76777


Field	Value
OBJECTID	363
Shape	Point
KrvID	204.z_4
mKvID	204.z_698555_7677069
ProfilID	1
dL	1350,000000
dH	143,451116
Xstart	699399,014984
Ystart	7677868,342053
Hstart	389,630998
Xslutt	698555,891489
Yslutt	7677069,643723
Hslutt	533,082114
Utlopid	4
Vannforing	0,215244
Effekt	370,524481
NedbFeltAreal	5,70625
AvstKrl	1901,4797
AvstVeg	1500,8331
Produksjon	1,515377
VeiKost	750,41655
LedningsKost	665,517895
TotalKost	6133,875129
PrisPrKWh	4,047757
Vassdragsnr	204.80
ProdFaktor	0,7
KommNr	1939
Verneplan_id	
InntakIVatn	0
Dato	20040126



Method of production

- Calculate for each drainage basin
 - Divide depending of size
- Append in a seamless PGDB
 - Use "load data"
- Quality control in ArcView
 - Manuel check
 - The results from the automatic method pass a manual quality control before acceptance and the method and its results are approved by experts.

Outcome





Comments


- Location are accurate, but does not give a correct location for planning new power
- **Gives the theoretical potential for small hydro power plants.**
- Is **NOT** a map showing where new power plant are going to be build
- An development will take other factors into account and will nearly always end in a different location of both intake and plant.



Experience


Correct river network essential

- Important that all river reaches have direction towards outlet
- Parallel river reaches – Some OK other not OK
- Topology in network before building geometric network – ensure no topologic errors
 - No double lines
 - no intersections
 - Outlet snapped to river



Geometric river network

- Most frequent errors
 - Wrong direction
 - Rivers are connected at watershed divide
 - More than one outlet in a lake from one river



A problem arise in the future calculations if the data is not correct



Further work

- Quality control by surveying some regions by foot
- Better data with transmission lines
- Develop an interactive method for calculate parameters depending of set location of intake and power plant.



Weakness

- DTEM
- Transmission lines
- Horizontal distance to rivers and lines
- Should have set limits on steep river slopes (maximum)



Automatic method

- ArcMap document with relative paths and set structure of catalog's
 - Easy to calculate a new area
- Programmed in VBA and stored in the mxd-file.
- The Program can run in steps or total automatic.

Beregn profil

Beregn fall

HydroBeregning

TotalBeregning



Parameters

Beregning av potensiale for mikro kraft... ✕

Vassdragsnr	<input type="text" value="204.z"/>	Minimumseffekt	<input type="text" value="50"/>
DeltaLengde	<input type="text" value="50"/>	Maksimumseffekt	<input type="text" value="5000"/>
Slukeevne	<input type="text" value="1.5"/>	Min. fallhøyde	<input type="text" value="10"/>
Min dH/dL	<input type="text" value="0.04"/>	Maks. fallhøyde	<input type="text" value="600"/>
MinVannføring	<input type="text" value="0.05"/>	Effektfaktor	<input type="text" value="8"/>
MaksVannføring	<input type="text" value="25"/>	Varighetsfaktor	<input type="text" value="0.7"/>

Antall valgte utløpspunkter: 197



Challenges in the programming

- Efficiency
- Sturdy program
- Advanced use of ArcObjects
- Integration with MS Office



Challenges in the programming

- Efficiency
 - One analyse can run for more than one 24-hour period
 - No calculations are done more than once. Data are temporary saved in memory
 - Use small analyse area when running some of the raster calculations. (3x3 cells)



Challenges in the programming

- Sturdy program
- Stops because of unknown reasons
 - The Program can continue whiteout losing already calculated data



Challenges in the programming

- Advanced use of ArcObjects
 - Spatial analyst
 - Upstream area
 - Runoff in point of intake
 - Distance to transmission lines/roads
 - Utility network analyst
 - Make profiles along all rivers from outlet all the way to the source of each tributary



Challenges in the programming

- Integration with MS Office
 - Use cost accounting formula in excel
 - Store the result report in excel

Inndata fra GIS		
Brutto fallhøyde	255.100826	m
Lengde rørgate	2 003	m
Slukevne	0.49	m ³ /s
Lengde veg	10408.6504	m
Lengde linje	12124.4844	m
Effekt	1004	kW
Konstanter i konstnadsfunksjoner		
Vannhastighet	3.0	m/s
Rente	8 %	
Byggetid	8	mnd
Kostnader		
	Tusen kr	
Totalkostnad	20979	
herav:		
Linje	4 244	
Veg	5204.3252	

KrvID	Fallhøyde	Potensial for Mikrokraftverk			Produksjon	AvstKrL	AvstVeg	Totalkost	Linjekost	Vegkost	PrisPrkWh
		NedbFeltAre	Vannføring	Effekt							
204.z_1	11.1	103.86	3.191	423	1.7	293	230	7266.2	102.4	115.2	4.20
204.z_2	11.3	90.07	2.807	380	1.6	190	90	7009.6	66.6	45.1	4.52
204.z_3	287.1	11.21	0.393	1354	5.5	1107	584	9870.3	387.5	291.8	1.78
204.z_4	143.5	5.71	0.215	371	1.5	1901	1501	6133.9	665.5	750.4	4.05
204.z_5	97.3	3.92	0.140	163	0.7	1901	1501	4330.8	665.5	750.4	6.48
204.z_6	434.3	4.97	0.150	783	3.2	425	79	6595.3	148.8	39.5	2.06
204.z_7	406.3	2.99	0.113	552	2.3	474	25	4620.2	166.0	12.5	2.05
204.z_8	14.3	24.91	0.841	144	0.6	0	112	3452.1	0.0	55.9	5.85
204.z_9	601.7	1.15	0.082	595	2.4	195	0	5015.9	68.3	0.0	2.06
204.z_10	305.2	9.86	0.420	1538	6.3	230	50	11306.5	80.7	25.0	1.80
204.z_11	13.4	9.14	0.393	63	0.3	2085	1145	2891.3	729.8	572.5	11.15
204.z_12	93.7	1.21	0.071	79	0.3	2524	1981	4404.5	883.5	990.6	13.58